

AP 04

Test report C/23491/T01a Test 8 Spec 276
Pavane MDF panel, 3mm perforations at 8mm centres,
50mm Rockwool backing
Sound absorption coefficient BS EN ISO 354: 0.60
BS EN ISO 11654: Class C

