

AP 05

Test report C/23491/T01a Test 10 Spec 274
Sonata MDF panel, 5mm perforations at 16mm centres,
50mm Rockwool backing
Sound absorption coefficient BS EN ISO 354: 0.45
BS EN ISO 11654 Class D

