

## AP 06

Test report C/23491/T01a Test 9 Spec 273

Overture MDF panel, 3mm perforations at 16mm centres,  
50mm Rockwool backing

Sound absorption coefficient BS EN ISO 354: 0.30

BS EN ISO 11654: Class D

