



Certificate of Test: Chilt/P04009/B

This certificate is awarded to:

Primary Sponsor
F R Shadbolt & Sons Ltd
North Circular Road
South Chingford
London
E4 8PZ


Secondary sponsors
Yannedis Ltd
Riverside House
Southend Road
Woodford green
Essex
IG8 8HQ


Stanton Interior Solutions Ltd
Laxcon Close
Drury Way
London
NW10 0TG

This document confirms that life cycle and durability performance testing to DD171, EN1192, PAS 23 and Cycle testing to the principles of EN 1191, was conducted on your doorset specimens from 23 April 2004 to 26 May 2005 and the following results were achieved.

Summary of testing procedure	Result
DD171 Clauses 4.3, 4.4, 4.9, 4.10, 4.11	Severe duty
EN947, EN948, EN949 and EN950 (with classification according to EN 1192)	Severe duty
EN 1191 (with classification according to EN 12400)	Completed 1,000,000 cycles Class 8, Severe duty
Operating forces evaluated according to PAS 23 Clause 6.3 throughout testing	

The results relate only to the specimens tested, as detailed in technical specification document number Chilt/P04009/tec2


Paul Andrews – Senior Test Engineer
Date: 16 December 2005


Vincent Kerrigan – Deputy Testing Manager
Date: 16 December 2005

Chiltern Dynamics
Chiltern House, Stocking Lane, Hughenden Valley,
High Wycombe, HP14 4ND, United Kingdom
Tel: 01494 569800
Fax: 01494 564895

Web: www.chilterndynamics.co.uk
Email: cd@chilterndynamics.co.uk

Page 1 of 1



This document is confidential and remains the property of Chiltern International Fire Ltd

1762