



## Certificate of Test: Chilt/P04009/A

This certificate is awarded to:

Primary Sponsor  
F R Shadbolt & Sons Ltd  
North Circular Road  
South Chingford  
London  
E4 8PZ


Secondary sponsors  
Yannedis Ltd  
Riverside House  
Southend Road  
Woodford green  
Essex  
IG8 8HQ


Stanton Interior Solutions Ltd  
Laxcon Close  
Drury Way  
London  
NW10 0TG

This document confirms that life cycle and durability performance testing to DD171, EN1192, PAS 23 and Cycle testing to the principles of EN 1191, was conducted on your doorset specimens from 11 March 2004 to 20 May 2005 and the following results were achieved.

Summary of testing procedure	Result
DD171 Clauses 4.3, 4.4, 4.9, 4.10, 4.11	Severe duty
EN947, EN948, EN949 and EN950 (with classification according to EN 1192)	Severe duty
EN 1191 (with classification according to EN 12400)	Completed 1,000,000 cycles Class 8, Severe duty
Operating forces evaluated according to PAS 23 Clause 6.3 throughout testing	

*The results relate only to the specimens tested, as detailed in technical specification document number Chilt/P04009/tec1*

  
Paul Andrews – Senior Test Engineer  
Date: 16 December 2005

  
Vincent Kerrigan – Deputy Testing Manager  
Date: 16 December 2005

**Chiltern Dynamics**  
Chiltern House, Stocking Lane, Hughenden Valley,  
High Wycombe, HP14 4ND, United Kingdom  
Tel: 01494 569800  
Fax: 01494 564895

Web: [www.chilterndynamics.co.uk](http://www.chilterndynamics.co.uk)  
Email: [cd@chilterndynamics.co.uk](mailto:cd@chilterndynamics.co.uk)

Page 1 of 1



1762

This document is confidential and remains the property of Chiltern International Fire Ltd